

Thermal

Critical Charging Discharging Thermal Remote SoC limits TempView VoltView




Edit

Statu

Setuj



Cooling parameters

Mode OFF state

| | Monitor | Threshold | Gap | Actual | State | Delay transition |
|-----------------|--|---------------------------------|---|-----------------------------------|-----------------------------|---|
| Hi Cell Celcius | On  | <input type="text" value="42"/> | <input type="text" value="5"/> CT5 | <input type="text" value="21"/> | <input type="checkbox"/> °C | Stop <input type="text" value="60.0"/> sec |
| Hi Ambient | On  | <input type="text" value="47"/> | <input type="text" value="5"/> BT5 | <input type="text" value="21"/> | <input type="checkbox"/> °C | Restart <input type="text" value="30.0"/> sec |
| In Bypass | On  | | | <input type="text" value="0.00"/> | <input type="checkbox"/> A | |

Heating parameters

Mode OFF state

| | Monitor | Threshold | Gap | Actual | State | Delay transition |
|-----------------|---|--------------------------------|---|---------------------------------|-----------------------------|---|
| Lo Cell Celcius | Off  | <input type="text" value="5"/> | <input type="text" value="5"/> CT4 | <input type="text" value="19"/> | <input type="checkbox"/> °C | Stop <input type="text" value="60.0"/> sec |
| Lo Ambient | On  | <input type="text" value="0"/> | <input type="text" value="5"/> BT4 | <input type="text" value="21"/> | <input type="checkbox"/> °C | Restart <input type="text" value="45.0"/> sec |

Revision #1

Created 6 March 2023 17:03:06 by Admin

Updated 6 March 2023 17:03:06 by Admin