

CellMon

System **CellMon** Shunt Expansion Integration

Edit

Batt Type

Custom

Lo Cell Voltage **CV2**

2.80

 V

Nom. Cell Volt **CV7**

3.20

 V

Bypass Volt **CV9**

3.45

 V

Hi Cell Voltage **CV11**

3.65

 V

Lo Cell Celcius

-5

 °C

Hi Cell Celcius **CT8**

55

 °C

Ignore Lo Celcius

-40

 °C

CellMon Type

Cellmate K9 16-3s

Bypass Current Limit

0.72

 A

Bypass Temp Limit

75

 °C

Bypass Impedance

4.0

 Ohm

Bypass Extra Mode

None

Has Satellite

Off

Grp Range

1

Entire Range

1

First Cell ID

32

Last Cell ID

32

Dif Nominal

Off

Nom Series

32

Poller Mode

Normal

Status

Running

Cell Volt

3.33

3.34

 V

Cell Temp

19

21

 °C

Repeat

6700

Ticks

95 / 41

 TX / RX

Network Tester

StatusRx

SetupRx

Device Sync

Bypass Tester

Device Led Identifier

Cellmon Calibrator

More

More

Revision #1
Created 6 March 2023 16:59:32 by Admin
Updated 6 March 2023 16:59:32 by Admin