

CellMon

System **CellMon** Shunt Expansion Integration

Edit

Batt Type

Custom

Lo Cell Voltage

CV2

2.80

V

Nom. Cell Volt

CV7

3.20

V

Bypass Volt

CV9

3.45

V

Hi Cell Voltage

CV11

3.65

V

Lo Cell Celcius

-5

°C

Hi Cell Celcius

CT8

55

°C

Ignore Lo Celcius

-40

°C

CellMon Type

Cellmate K9 16-3s

Bypass Current Limit

0.72

A

Bypass Temp Limit

75

°C

Bypass Impedance

4.0

Ohm

Bypass Extra Mode

None

More

Has Satellite

Off

Grp Range

Entire Range

First Cell ID

1

1

Last Cell ID

32

32

Dif Nominal

Off

Nom Series

32

Poller Mode

Normal

More

Status

Running

Low

High

Cell Volt

3.33

3.34

V

Cell Temp

19

21

°C

Repeat

6700

Ticks

95 / 41

TX / RX

Network Tester

StatusRx

SetupRx

Device Sync

Bypass Tester

Device Led Identifier

Cellmon Calibrator

Revision #1
Created 6 March 2023 16:59:32 by Admin
Updated 6 March 2023 16:59:32 by Admin